



KARNATAKA GOVERNEMENT  
TALUK HEALTH OFFICE BANGALORE EAST TALUK K R PURAM BANGALORE  
PHONE NO-:080-25612400 E MAIL ID - thobangaloreeast2@gmail.com

REF: THO/NO:54/2024-25

DATE: 29-05-2025

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

It is certified that an inspection team headed by Dr. BB RAGUNATH I/C Taluk Health Officer From Taluk Health Office, Bangalore East Taluk, Bangalore Urban District. Health and family welfare Department inspected the **GLENTREE ACADEMY- WHITEFIELD, NALLURAHALLI, WHITEFIELD, BANGALORE EAST TALUK, BANGALORE- 560066** run by **SRI VENKATESWARA TRUST** on 29-05-2025 checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt .

The above is valid for period of One Year till 29-05-2026

Signature : Dr. BB RAGUNATH

Designation :TALUK HEALTH OFFICER

To,  
THE CHAIRMAN/ Principal  
GLENTREE ACADEMY- WHITEFIELD  
NALLURAHALLI,  
WHITEFIELD,  
BANGALORE- 560066.

**TALUK HEALTH OFFICE**  
**East Taluk, K.R.Puram**  
**Bangalore Urban District**





# AES TESTING LABORATORY

(ISO 9001:2005/ISO45001:2018 Certified Laboratory)

# 44, 45, 1st Main Road, Vinayaka Nagar, Bagalagunte, Nagasandra Post, Bangalore - 560 073.

Mob : 9538555792, 9538555283, 9000565208, Email : aestestinglaboratory@gmail.com Web : www.aeslabs.co.in

## TEST REPORT

Page: 1 of 1

Report No: AESTL/25/05/W/0646	Report Date :28/05/2025
Issued To: M/s. Glentree Academy School Whitefield Nalluralli Main Road, Palm Meadows , Nalluralli Whitefield , Bangalore-60.	Customer Reference: Verbal
	Date of Receipt : 24/05/2025
	Date of test Start : 24/05/2025
	Date of Completion of test: 28/05/2025
Sample Collected By: Customer	Sample Particulars : R.O Water


## Analytical Result

Sl. No	Tests	Results	Maximum Acceptable Limits (in mg/L)	Maximum Permissible Limits (in mg/L)	Protocol
			(As per IS 10500:2012)		
01	Colour, Hazen Units	<1.0	5	15	APHA 2120 B
02	Odour	Agreeable	Agreeable	Agreeable	APHA 2150 C
03	Turbidity, NTU	<1.0	1	5	APHA 2130 B
04	pH Value	7.1	6.5 - 8.5	No Relaxation	APHA 4500 H+ B
05	Electrical conductivity, $\mu\text{S}/\text{cm}$	68.83			APHA 2510B
06	Total Hardness as $\text{CaCO}_3$ , mg/L	9.0	200	600	APHA 2340 C
07	Calcium as Ca, mg/L	2.0	75	200	APHA 3500 Ca
08	Magnesium as Mg, mg/L	1.0	30	100	APHA 3500 Mg - B
09	Chloride as Cl, mg/L	8.0	250	1000	APHA 4500 Cl
10	Total Dissolved Solids, mg/L	44.36	500	2000	APHA 2540 C
11	Sulphate as $\text{SO}_4$ , mg/L	2.0	200	400	APHA 4500 $\text{SO}_4$ - E
12	Nitrate as $\text{NO}_3$ , mg/L	1.8	45	No Relaxation	IS 3025 Part 34
13	Fluoride as F, mg/L	<0.1	1.0	1.5	APHA 4500 F- D
14	Iron as Fe, mg/L	<0.05	0.3	No Relaxation	APHA 3500 Fe
15	Total Alkalinity as $\text{CaCO}_3$ , mg/L	20.0	200	600	APHA 2320 B
16	Total Coliform MPN/100ml	Absent	Absent		IS :15185:2016 (Ref 2021)
17	E.Coli MPN/100ml	Absent	Absent		IS :15185:2016 (Ref 2021)

Remarks: The above given parameter of given water sample meets to Acceptable limits as per

IS 10500: 2012 for above chemical and Microbiological test .

\*\*\*\*\*End of the Report\*\*\*\*\*

Tested By: 

Authorized Signature: 

Note : 1. The Result listed pertain only to tested samples and applicable parameters. 2. Samples will be destroyed after 15 days from the date of issue of test certificate unless & otherwise Specified. 3. This Report is not be reproduced either wholly or in part and can not be used an evidence in the count of law and should not any adverting media without prior Written permission. 4. Sampling not done by us, unless specified.