



KARNATAKA GOVERNEMENT

TALUK HEALTH OFFICE BANGALORE EAST TALUK K R PURAM BANGALORE
PHONE NO--:080-25612400 E MAIL ID - thobangaloreeast2@gmail.com

REF: THO/NO:10/2026-27

DATE: 17-04-2026

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
 CONDITON CERTIFICATE**

It is certified that an inspection team headed by **Dr. B. B. RAGHUNATH I/C Taluk Health Officer** from **Taluk Health Office, Bengaluru East Taluk, Bengaluru Urban District, Health and Family Welfare Department** inspected the **GLENTREE ACADEMY – WHITEFIELD, Nallurahalli, Whitefield, Bengaluru East Taluk, Bengaluru– 560066** run by **SRI VENKATESWARA TRUST ®** on 17-04-2026 and on the basis of Water Test Report (attached), bearing no. PHI/Water/BAC/1632/2025-26 dated 23-03-2026 of Office of the Joint Director, Public Health Institute, Bengaluru – 560 001 (PHI Lab) certified that the **GLENTREE ACADEMY – WHITEFIELD, Nallurahalli, Whitefield, Bengaluru East Taluk, Bengaluru– 560066** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic condition in the School building and the campus as per the norms prescribed by the Central/State/U.T Government.


This certificate is valid for a period of One Year.

Signature with seal:

Name

Designation

Name & Address of the office/department :


TALUK HEALTH OFFICER
East Taluk, K.R.Puram
Bangalore Urban District

To
The Principal,
GLENTREE ACADEMY – WHITEFIELD,
Nallurahalli,
Whitefield,
Bengaluru East Taluk,
Bengaluru– 560066

Report of Bacteriological analysis of Water Sample

Date: 23/03/2026

Principal Glenree Academy White Field Nallurhalli White Field Bengaluru - 560066	Opinion							
	Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
	5352	Ro water	Nil	—	—	SPP	—	—
<p>Note: M.P.N. Count: Most Potable number of Bacteria Per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coli found</p>								

0	0-1-A	01	01	01	01	01	01	01
0	0-1-A	01	01	01	01	01	01	01

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE,
Bengaluru

(PTO)

Товчоогийг хийж, төгсгөлд
 100002 - үргэлжлүүлж
 1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More