



**KARNATAKA GOVERNEMENT**

**TALUK HEALTH OFFICE BANGALORE EAST TALUK K R PURAM BANGALORE**  
**PHONE NO--:080-25612400 E MAIL ID - thobangaloreeast2@gmail.com**

REF: THO/NO:11/2026-27

DATE: 17-04-2026

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY  
 CONDITON CERTIFICATE**

It is certified that an inspection team headed by **Dr. B. B. RAGHUNATH I/C Taluk Health Officer** from **Taluk Health Office, Bengaluru East Taluk, Bengaluru Urban District, Health and Family Welfare Department** inspected the **GLENTREE ACADEMY, Halanayakanahalli, Varthur Hobli, Bengaluru East Taluk, Bengaluru- 560035** run by **GLENTREE EDUCATION TRUST ®** on 17-04-2026 and on the basis of Water Test Report (attached), bearing no. PHI/Water/BAC/1647/2025-26 dated 24-03-2026 of Office of the Joint Director, Public Health Institute, Bengaluru - 560 001 (PHI Lab) certified that the **GLENTREE ACADEMY, Halanayakanahalli, Varthur Hobli, Bengaluru East Taluk, Bengaluru- 560035** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic condition in the School building and the campus as per the norms prescribed by the Central/State/U.T Government.

This certificate is valid for a period of One Year.

Signature with seal: **TALUK HEALTH OFFICER**  
 Name : **East Taluk, K.R.Puram**  
 Designation : **Bangalore Urban District**

Name & Address of the office/department :

**B B Raghunath**

To  
**The Principal,**  
**GLENTREE ACADEMY,**  
**Halanayakanahalli,**  
**Varthur Hobli,**  
**Bengaluru East Taluk,**  
**Bengaluru- 560035**

Report of Bacteriological analysis of Water Sample

Date: 24/03/2026

Sample No	Source & Particulars of Water Sample	Opinion					
		M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
5407	RO Water	NIL	—	—	SPP	—	—

Principal  
Glenree Academy  
Sasrapur Road, BFD  
South-H, NO 365,  
Halannayakana Halli  
Vasanth Mohli  
Bangalore-560035

Note:  
M.P.N. Count:  
Most Potable number of Bacteria Per  
100ml of Water  
D.C Test:  
Differential Coliform test  
Plate Count:  
Plate Count per ml of sample  
SPP:  
Water is satisfactory for Potable  
purpose  
NSPP:  
Water is not satisfactory for  
Drinking purpose  
NSPP & FC:  
Water is not satisfactory for  
Drinking purpose and E. Coli found

For Joint Director (Labs)  
PUBLIC HEALTH INSTITUTE,  
Bengaluru

(PTO)

Office of Joint Director  
 Advice: 1. Sample .....

Need effective chlorination before

2. Sample .....

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

**STANDARD FOR THE DRINKING WATER**

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More